



Mobile Food Vendor Inspection Form

Davenport Fire Prevention Bureau

Phone: 563-888-2175

Date: _____

Name of Company: _____

Address: _____

Contact Person: _____ Phone: _____

Email: _____

Vehicle Information

Make: _____ Model: _____ License Plate: _____

___ Exhaust Hood-Type I (Referenced; 2012 IFC section 609.2)

___ Filters

___ Cleaning

___ Tags

___ Records

___ Fire Extinguishing System

___ Fire Extinguishers (Referenced 2012 IFC Section 904.11.5)

___ 2A-20BC

___ Class K

___ **LP System** (Referenced NFPA 58, 2014 Edition, Section 6.24)

___ Tanks (Max 2- 20 LBS Tanks)

___ Tank mounting (6.24.3.4)

___ Shutoff valve readily accessible (6.24.4.1)

___ Caution plate (6.24.7.10)

___ Outside storage (6.24.3.4 A,B,C,D,E,F,G,H)

___ Inside storage (Vapor tight cabinet) (6.24.3.3; 6.24.3.4 I)

___ Regulators (Protected) (6.24.4.2 B)

___ Hoses (350 PSI, marked LP gas)

___ Fixed piping (6.24.5)

___ Fastened (6.24.5.1)

___ Flexible connectors (6.24.5.1 B)

___ Rubber grommets at pass through points (6.24.5.1 H(3))

___ **Egress** (NFPA 58 section 6.24.7.9)

___ **Electrical** (NFPA 58 section 6.24.7.9)

___ **General Housekeeping/Storage** (2012 IFC section 315.1)

Based on the inspection completed above, the mobile food truck referenced in the information above:

___ **MEETS COMPLIANCE**

___ **DOES NOT MEET COMPLIANCE**

Inspector: _____ **Signature:** _____

Vendor: _____ **Signature:** _____